

Palo Verde Nuclear Generating Station David Mauldin Vice President Nuclear Engineering and Support

TEL (623) 393-5553 FAX (623) 393-6077 Mail Station 7605 P.O. Box 52034 Phoenix, AZ 85072-2034

102-04989-CDM/TNW/RMW August 22, 2003

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Mail Station P1-37 Washington, DC 20555

References:

1. Letter No. 102-04641-CDM/RAB, dated December 21, 2001, from C. D. Mauldin, APS to U. S. Nuclear Regulatory Commission, "Request for a License Amendment to Support Replacement of Steam Generators and Uprated Power Operations".

2. ABB Combustion Engineering Nuclear Fuel Topical Report CEN-386-P-A, "Verification of the Acceptability of a 1-Pin Burnup Limit of 60 MWD/kgU for Combustion Engineering 16x16 PWR Fuel", dated August 1992.

3. NRC Letter from Ashok C. Thadani, USNRC, to Mr. A. E. Scherer, Combustion Engineering, dated June 22, 1992, "Generic Approval of C-E Topical Report CEN-386-P-A, "Verification of the Acceptability of a 1-Pin Burnup Limit of 60 MWD/kgU for Combustion Engineering 16x16 PWR Fuel" (TAC NO. M82192)".

Dear Sirs:

Subject:

Palo Verde Nuclear Generating Station (PVNGS)

Unit 2, Docket No. STN 50-529

Response to Request for Additional Information Regarding Steam Generator Replacement and Power Uprate License

Amendment Request

In Reference 1, Arizona Public Service Company (APS) submitted a license amendment request to support steam generator replacement and uprated power operations for PVNGS Unit 2. During a conference call held between the NRC staff and APS on August 15, 2003, the staff requested additional information regarding cladding oxidation for zircaloy-clad fuel. This information can be obtained from Figure 4.1.2.a-1, Oxide vs. Burnup, page 8, of Reference 2. Please note the following with respect to the information provided in this figure and Reference 2:

4001

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Response to Request for Additional Information Regarding Steam Generator Replacement and Power Uprate License Amendment Request Page 2

- 1. The information contained in Reference 2 is ABB Combustion Engineering Nuclear Fuel (now Westinghouse Electric Company LLC) proprietary information,
- 2. Reference 2 has received generic NRC approval as documented in Reference 3,
- 3. Fuel rod details are provided on page 73 of Reference 2, Table 4.2.7.a-1, and
- 4. The oxide information provided in Figure 4.1.2.a-1 must be converted from oxide thickness into the percent amount of zircaloy cladding wastage that occurs when oxidation occurs. This conversion process is described below.

Oxide thickness, in microns, can be converted into the percent amount of zircaloy cladding wastage using the following equations:

Zircaloy cladding wastage (μ m) = oxide thickness (μ m)/1.56 (based on information taken from Figure 4.1.2.a-1 of Reference 2, and the volumetric difference between zircaloy cladding oxide and pure zircaloy cladding. One oxide molecule occupies 1.56 times as much volume as one pure zircaloy cladding molecule)

Original zircaloy cladding thickness (μm) = original zircaloy cladding thickness (mils) x 25.4 (original zircaloy cladding thickness can be determined from information provided in Table 4.2.7.a-1 of Reference 2, and on the conversion factor of 1 mil = 25.4 μm)

Percent zircaloy cladding wastage = (zircaloy cladding wastage (μ m)/original zircaloy cladding thickness (μ m))x100

An example of the above conversion process is provided below. Assume that the initial zircaloy cladding thickness is 25 mils and that the oxide thickness, in microns, for a rod average burnup of 40 MWD/kgU has been determined to be 40 μ m from Figure 4.1.2.a-1. Note that these assumed values are for illustration purposes only and they may not be representative of the actual values provided in Reference 2.

Zircaloy cladding wastage (μ m) = 40 μ m/1.56 = 25.64 μ m Original zircaloy cladding thickness (μ m) = 25 mils x 25.4 μ m/mil = 635 μ m Percent zircaloy cladding wastage = (25.64 μ m/635 μ m)x100 = 4.04%

As can be seen from this example, determining the percent amount of zircaloy cladding wastage from the information provided in Reference 2 is a straightforward conversion process.

U. S. Nuclear Regulatory Commission

ATTN: Document Control Desk

Response to Request for Additional Information Regarding Steam Generator

Replacement and Power Uprate License Amendment Request

Page 3

This letter does not contain any proprietary information, nor are any commitments being made to the NRC in this letter.

Should you have any questions, please call Thomas N. Weber at (623) 393-5764.

Sincerely,

CDM/TNW/RMW

cc: Regional Administrator

J. N. Donohew

M. B. Fields

N. D. Ticiac

N. L. Salgado

A. V. Godwin

(NRC Region IV)

(NRR Project Manager)

(NRR Project Manager)

(NRC Senior Resident Inspector)

(ARRA)

Attachment:

1. Notarized Affidavit

Attachment 1

STATE OF ARIZONA)	
) ss. COUNTY OF MARICOPA)	
Support, Arizona Public Service (signed by me on behalf of APS	nt that I am Vice President Nuclear Engineering and Company (APS), that the foregoing document has been with full authority to do so, and that to the best of my ents made therein are true and correct.
	Davidon
	David Mauldin
Sworn To Before Me This 22nd	Day Of August, 2003.
	- Charen Greene,
OFFICAL SEAL Karen D. Greine NOTARY PUBLIC - STATE of MARICOPA COUN MY COMM. EXPIRES AUGUS	ARIZONA TY

Notary Commission Stamp